Standard Form Number: SF-GOOD-30 Revised on: Mat 24, 2004

## Republic of the Philippines MARINDUQUE STATE COLLEGE

Tanza, Boac, Marinduque Tel Nos.: (042) 332-0662 loc. 114 mscbac2011@gmail.com

## **BID BULLETIN**

This Bid Bulletin No. 03 is issued to inform all concerned regarding the items for clarifications for the Construction of MSC Learning Resource Center and Museum. They are as follows:

- Building Permit The municipal engineering office is charging the contractor for the building permit because they included the permit as a pay item in their BOQ, but if they did not include the permit as pay item, the contractor shall not be charged. Therefore, it is better to not include the building permit in the contractors BOQ.
- 2. 2A) Doors If the door frame is aluminum, then the jamb would also be aluminum, but for the machine rooms, louvers are made up of steel.
  - 2B) D1, D2,D3 Materials for the jambs should be steel and panel doors are woodened.
  - 2C) Glass Doors Glass doors shall be frameless with the minimum thickness of 12mm.
- 3. Window panels windows shall be ¼ inch thickness on aluminum frame.
- Stairs standard-price shades regardless of colors.
- 5. Deck slab 1:80 but not less than 5 inches.
- Cistern tank they have the same structural details (cistern tank and septic tank) because they are both tanks. However, they have different functions.
   Septic tanks are for the waste while cistern tank is for the water supply and that should be located separately.
- Water tank water tank with the capacity of 1000 liters with 1 horse power electric pump and the pressure tank sufficient to supply the 1000 liters with auto-shut off.
- 8. Fire protection the fire protection is normally a packaged item with suppliers having different application and branding with regards to the particular connection and setting. Please refer to your legit suppliers because it comes with warranties.
  - Fire suppressant FM-200 material is included as well as all the requirements of the system as follows: fire alarm bell/horn, smoke detector, control panel,

A Supplemental / Bid Bulletin is a notice issued by the Procuring Entity to Eligible Bidders with respect to any clarifications or modifications in the Bidding Documents, including those affecting the technical specifications, procurement schedule, and other similar matters. It is prepared by the TWG, approved by the BAC, and publicized by the BAC Secretariat. It should be made available to all Prospective Bidders who have properly secured or purchased the Bidding Documents, not later than seven (7) calendar days before the deadline for the submission and receipt of bids.

Standard Form Number: SF-GOOD-30 Revised on: Mat 24, 2004

nozzle discharge tip is preferred, connectors, manual brakes, illuminated exit signs, release abort stations and others.

This is also to inform all concerned that the opening of bids is moved from August 30, 2018 to September 10, 2018/2:00PM.

For guidance and information of all concerned.

DR. DIOSDADO P. ZULUETA BAC Chairperson

Received by the Bidder:	
Date:	i

A Supplemental / Bid Bulletin is a notice issued by the Procuring Entity to Eligible Bidders with respect to any clarifications or modifications in the Bidding Documents, including those affecting the technical specifications, procurement schedule, and other similar matters. It is prepared by the TWG, approved by the BAC, and publicized by the BAC Secretariat. It should be made available to all Prospective Bidders who have properly secured or purchased the Bidding Documents, not later than seven (7) calendar days before the deadline for the submission and receipt of bids.